



Product Service

CERTIFICATE

No. Z2 068988 0129 Rev. 00

Holder of Certificate: **Jetion Solar (China) Co., Ltd.**

No. 1011, Zhencheng Rd.,
Shengang Industrial District
214443 Jiangyin
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062419012-00

Valid until: 2029-12-12

Date, 2024-12-13

(Zhulin Zhang)



CERTIFICATE

No. Z2 068988 0129 Rev. 00

Model(s):

JTxxxSGt, xxx=560 to 590, in steps of 5
 JTxxxSFt, xxx=505 to 540, in steps of 5
 JTxxxSHt, xxx=460 to 490, in steps of 5
 JTxxxSEt, xxx=410 to 440, in steps of 5
 JTxxxSEt (L), xxx=410 to 440, in steps of 5
 JTxxxSCt (L), xxx=280 to 295, in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou Hua Yang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2023
 IEC 61730-2:2023