



Product Service

Attestation of Conformity

No. N8A 068988 0118 Rev. 06

Holder of Attestation: **Jetion Solar (China) Co., Ltd.**

No. 1011, Zhencheng Rd.,
Shengang Industrial District
214443 Jiangyin
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061905601-07

Date, 2026-02-13

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 068988 0118 Rev. 06

Model(s):

JTxxxSSh, xxx=360 to 390, in steps of 5
 JTxxxSSh, xxx=430 to 445, in steps of 5
 JTxxxSIh, xxx=300 to 325, in steps of 5
 JTxxxSIh, xxx=355 to 370, in steps of 5
 JTxxxSSh(B), xxx=430 to 440, in steps of 5
 JTxxxSIh(B), xxx=355 to 365, in steps of 5
 JTxxxSRt(B), xxx=610 to 640, in steps of 5
 JTxxxSSt(B), xxx=555 to 590, in steps of 5
 JTxxxSLt(B), xxx=500 to 530, in steps of 5
 JTxxxSIh(B), xxx=460 to 490, in steps of 5
 JTxxxSJt(B), xxx=410 to 440, in steps of 5
 JTxxxSSh(B), xxx=530 to 555, in steps of 5
 JTxxxSLh(B), xxx=485 to 505, in steps of 5
 JTxxxSIh(B), xxx=435 to 455, in steps of 5
 JTxxxSJh(B), xxx=395 to 415, in steps of 5
 JTxxxSLk(B), xxx=640 to 670, in steps of 5
 JTxxxSIk(B), xxx=580 to 600, in steps of 5
 JTxxxSZk(B), xxx=530 to 550, in steps of 5
 JTxxxSSh(B) Carport A-R, xxx=450 to 460, in steps of 5
 JTxxxSSh(B) Carport A-L, xxx=450 to 460, in steps of 5
 JTxxxSJh(B) Carport B-R, xxx=335 to 345, in steps of 5
 JTxxxSJh(B) Carport B-L, xxx=335 to 345, in steps of 5
 JTxxxSLk(B), xxx=685 to 720, in steps of 5
 JTxxxSIk(B), xxx=620 to 650, in steps of 5
 JTxxxSZk(B), xxx=570 to 600, in steps of 5
 JTxxxSJk(B), xxx=570 to 590, in steps of 5
 JTxxxSNk(B), xxx=505 to 525, in steps of 5
 JTxxxSYk(B), xxx=420 to 440, in steps of 5
 JTxxxSLt(B), xxx=605 to 650, in steps of 5
 JTxxxSJt(B), xxx=495 to 525, in steps of 5
 JTxxxSNt(B), xxx=440 to 460, in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed or Frameless with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. B Area on 1/F., Building 12, C Area on 4/F., and A Area on 1/F., Building 10, No. 8, Lanxiang Road, West Taihu Science and Technology Industrial Park, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class B or Class C according to UL790.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-2:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.