



Product Service

CERTIFICATE

No. Z2 068988 0124 Rev. 04

Holder of Certificate: **Jetion Solar (China) Co., Ltd.**
No. 1011, Zhencheng Rd.,
Shengang Industrial District
214443 Jiangyin
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062319003-04

Valid until: 2031-02-09

Date, 2026-02-11

(Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 068988 0124 Rev. 04

Model(s):

JTxxxSLk(B), xxx = 685 to 745, in steps of 5
JTxxxSlk(B), xxx = 620 to 675, in steps of 5
JTxxxSZk(B), xxx = 570 to 600, in steps of 5
JTxxxSjk(B), xxx = 570 to 610, in steps of 5
JTxxxSNk(B), xxx = 505 to 545, in steps of 5
JTxxxSYk(B), xxx = 420 to 440, in steps of 5
JTxxxSRt(B), xxx = 610 to 640, in steps of 5
JTxxxSSt(B), xxx = 560 to 590, in steps of 5
JTxxxSLt(B), xxx = 510 to 530, in steps of 5
JTxxxSlT(B), xxx = 460 to 490, in steps of 5
JTxxxSJt(B), xxx = 415 to 440, in steps of 5
JTxxxSLt(B), xxx = 605 to 650, in steps of 5
JTxxxSJt(B), xxx = 495 to 525, in steps of 5
JTxxxSNt(B), xxx = 440 to 460, in steps of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. B Area on 1/F., Building 12, C Area on 4/F., and A Area on 1/F., Building 10, No. 8, Lanxiang Road, West Taihu Science and Technology Industrial Park, Changzhou Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023